



**Information Technology Services  
Security Control Standards**

**NIST Control Family – Physical and Environmental Protection**

CONTROL NUMBER	CONTROL NAME	PRIORITY	REVISION DATE	NEXT SCHEDULED REVIEW DATE
PE-12	Emergency Lighting	P1	4/15/2020	4/15/2021

**I. Statement**

Tarleton employs and maintains automatic emergency lighting systems for the University computer center facility that activates in the event of a power outage or disruption and that covers emergency exits and evacuation routes within the facility.

**II. Applicability**

This Control applies to all Tarleton network information resources. The intended audience for this Control includes all information resource owners, custodians, and users of information resources.

**III. Risk Statement**

The lack of automatic emergency lighting during power outage or disruption may potentially disrupt continuity of business functions.

**IV. Implementation**

Information resource owners with responsibility over infrastructure equipment shall employ and maintain automatic emergency lighting for the information resource that activates in the event of a power outage or disruption and that covers emergency exits and evacuation routes within the facility.