



**Information Technology Services  
Security Control Standards**

**NIST Control Family – Physical and Environmental Protection**

CONTROL NUMBER	CONTROL NAME	PRIORITY	REVISION DATE	NEXT SCHEDULED UPDATE
PE-15	Water Damage Protection	P1	4/15/2020	4/15/2021

**I. Statement**

Tarleton protects data center information systems from damage resulting from water leakage by providing master shutoff or isolation valves that are accessible, working properly, and known to key personnel within the facilities department.

**II. Applicability**

This Control applies to all Tarleton network information resources. The intended audience for this Control includes all information resource owners, custodians, and users of information resources.

**III. Risk Statement**

The university protects the information system from damage resulting from water leakage by providing master shutoff or isolation valves that are accessible, working properly, and known to key personnel.

**IV. Implementation**

Information resource owners with responsibility over infrastructure equipment shall protect the information resource from damage resulting from water leakage by providing master shutoff or isolation valves that are accessible, working properly, and known to key personnel.